

MEMORANDUM

TO: Terry Jeffery
FROM: Mathieu Nicklay
DATE: 29 March 2022
RE: Status of March 2022 non-compliant sites

2/15 Permit # 2020-008 Eden Ridge Estates

Unprotected inlet downslope of excavated soil, soil piled on silt fence.
Status: Soil stockpile moved back from silt fence. Inlet still unprotected.

2/10 Permit # 2019-003 Stable Path

Biolog perimeter controls displaced.
Status: Uncorrected as of 3/17, additional issues have been revealed by melting of snow. EPSC representative has been notified.

2/10 Permit # 2021-046 Crossroads of Chanhassen Retail

Portion of silt fence down in NW corner.
Status: Uncorrected as of 3/15, additional issues revealed by melting snow. EPSC representative responded to email and confirmed issues will be taken care of.

Note: Due to the shutting down of many sites over winter, combined with the reduced likelihood of erosion and sediment discharge due to frozen soils, inspection frequency has been reduced to once per month for remaining active sites until spring. Twice a month inspections will resume in April.