

MEMORANDUM

TO: Terry Jeffery
FROM: Mathieu Nicklay
DATE: 6 September 2022
RE: Status of July 2022 non-compliant sites

07/12 Permit #2021-089 Nor-Son Eden Prairie Office

Perimeter controls missing along parking lot curb.

Status: All issues have been corrected

07/15 Permit #2019-007 Beverly Hills

Perimeter controls missing or displaced on active build lots.

Status: Perimeter control issues remain uncorrected.

7/18 Permit #2021-085 7851 Park Drive Storage Expansion

Silt fence is not sliced into the ground, leaving gap underneath.

Status: Corrected

7/18 Permit #2020-045 Galpin Project

Hydroseeding has failed due to dry conditions leaving slopes unstabilized.

Status: Rain has encouraged sprouting of previously applied hydroseeding. Growth is patchy and will be monitored to determine if reapplication is needed.

7/18 Permit #2019-051 Berrospid Addition

Perimeter control needs to be extended to fully contain disturbed areas.

Status: Corrected